

EBAC MODEL PD150 INDUSTRIAL DEHUMIDIFIER OWNER'S MANUAL



Ebac Industrial Products, Inc. 700 Thimble Shoals Blvd, Suite 109 Newport News, VA. 23606-2575 Tel: (757) 873 6800 Fax: (757) 873 3632

Website www.ebacusa.com



PD150

PACKAGE CONTENTS

Item	Description	Quantity
10150GY-US	Dehumidifier	1
3014338	PVC tube – 12mm I/D	3M
3086101	Jubilee clip	1
3037866	6 Pin Plug	1
TPC607	Manual	1



UNPACKING

Carefully remove the PD150 dehumidifier unit from its transit box and visually check for signs of transit damage. If there is evidence of damage DO NOT attempt to operate the unit, call your supplier for advice. Do not discard the packing, it will be useful when transporting the dehumidifier unit in the future.

INTRODUCTION

The Ebac PD150 industrial dehumidifier removes moisture from the air through the refrigeration process.

The Ebac PD150 is basically comprised of:

- 1) A compressor
- 2) A refrigerant evaporator coil
- 3) A refrigerant condenser coil
- 4) One circulation fan
- 5) A humidistat
- 6) A cabinet to house the above components

The fan draws the moist air through the cold evaporator coil which cools the air below its dew point. Moisture forms on the evaporator coil and is collected in the condensate tray which is equipped with a permanent drain. The cooled air then passes through the hot condenser coil where it is reheated using the same energy removed during the cooling phase, plus the additional heat generated by the compressor. The air is therefore discharged from the dehumidifier at a slightly higher temperature with a lower absolute humidity than with which it entered. Continuous circulation of air through the dehumidifier gradually reduces the relative humidity within the area.

The dehumidifier is a rugged, reliable drying unit designed to operate effectively over a broad range of temperature and humidity conditions.

The dehumidifier uses an internally mounted adjustable humidistat to enable you to select the level of dryness.

The unit can also be used with an external humidistat or the EIPL touch display panel (via the 6 pin connector) to control the level of dryness.



SPECIFICATIONS

MODEL:	Ebac PD150
Неіднт:	17.5" (443mm)
WIDTH:	27.5" (700mm)
D ЕРТН:	26" (660mm)
WEIGHT:	144 lbs (65Kg)
Airflow:	585 CFM (995 M3/hr)
Power:	1.9 KW
POWER SUPPLY:	220V / 60Hz / 1ph
FINISH:	Powder-coated Epoxy
Refrigerant Type/Qty:	R410a / 42.3oz (1.2Kg)



INSTALLATION

POSITIONING:

Position the dehumidifier unit in the center of the room to be conditioned if at all possible. However, if a damp patch is particularly apparent the outlet grille should be pointed towards it if possible.

This unit can also be used in a duct system where applicable, please see the diagrams on the following pages which identify the overall sizes of the unit and also the mounting points.

Connect the drainage outlet to a suitably sized hose and run the hose to a permanent drain.

Connect the unit power cable to a grounded power source.


NOTE:

Both inlet grille and outlet grille of the dehumidifier unit must have clear space around them and not be obstructed in anyway. For correct installation and operation, the unit inlet and outlet must have a clearance of 0.5M from all adjacent surfaces and or structures.

Optional Control Methods

1. External Humidistat

- Connections for an external humidistat are available on the 6 pin connector above the main isolator.
- The remote humidistat should have a normally open set of contacts which close on humidity rise.
- This connection is low voltage low current, suggested cable specification 2 core 16/0.2 (0.5mm) screened cable.
- Connection is across pins 5 and 6 of the 6 pin connector
- The Jumper on the main control board should be removed from position "E" to allow this feature to operate.





Drawing No. :- TPC607 Issue :- 1

Date :- 05/06/24

2. EIPL Touch Display Panel

- RS232 connections for the EIPL touch display panel are available on the 6 pin connector above the main isolator.
- Suggested cable specification 4 core 16/0.2 (0.5mm) screened cable.
- Connection details:-
 - Free Socket Pin 1 +12Vdc
 - o Free Socket Pin 2 RX
 - o Free Socket Pin 3 TX
 - o Free Socket Pin 4 0V







OPERATION



Button / Ledgend	Function	Description
	Menu	Cycle through menu options and adjust the desired set point. See below for list of menu options
S	Recirculation	Select recirculation fan or dehumidification mode
	Navigation	Adjust the humidity set point UP/DOWN and enter to confirm

Indicator	ndicator Function Description	
\bigcirc	ON/OFF	Green – On
	Drying / Recirculation	Blue – Flashing – Drying Required Blue – Solid – Drying On Green – Solid – Recirculation Mode (Fan Only)
*	Defrost	Yellow – Flashing – Defrost mode selected Yellow – Solid – Defrosting in progress
\bigcirc	Alarm	Red – Solid – Fault - High RH



Menu Options

Pressing the Menu button cycles through the following pages of information.

Menu Options when dehumidifying mode is selected

Menu	Display	Information	
1	Set RH	Using the Up / Down Keys adjust the humidity to the desired set- point, pressing the Enter key to accept and save.	
2	Temperature	Indicates the current room temperature.	
3	Coil Temp	Shows the current coil temperature. (< -9degC display "—")	
4	Time To Start	Displays the time to start drying (mins) or "on" if already drying	
5	Time To Defrost	If defrost mode is selected, this option shows the remaining tim until defrost will occur. The yellow defrost light will be flashing indicating a defrost is required.	
6	Time In Defrost	If defrost is currently occurring, the yellow defrost light will be solid, and the display will show the time remaining before defrost ends. Defrost not required or active the display will show "—"	
	Notes on Time values above		

2 digits no decimal point indicates a time > 10mins

2 digits with a decimal point indicates mins and tenths of a min, ie 8.5 = 8mins 30 secs

Menu Options when recirculation mode is selected

Menu	Display	Information
1	Humidity	Indicates the current room Humidity.

Operation

Plug the unit into a suitable wall socket and power on.

Set the Yellow/Red isolator switch to ON.

Note the Power On Indicator shows Solid Green.

To prevent the compressor starting too quickly after being powered down, there is an inbuilt compressor off timer. This delayed start prevents the compressor for restarting for 6 minutes after being switched off. Note this feature is reset when the isolator is set to OFF or power is removed from the unit.

The dehumidifier remembers the last mode of operation, and also the previously adjusted set point.



Drawing No. :- TPC607 Issue :- 1

Date :- 05/06/24

Once the dehumidifier is started, the drying / recirculation light will indicate the selected mode or operation.

Adjust the mode, as required. (Recirculation or Drying).

In drying mode, the display will show the room humidity level.

In recirculation mode the display shows the current room temperature.

Using the Menu Key cycle through the menu options to the Set RH page, using the up/down and enter keys adjust the humidity to the desired level.

The dehumidifier will now self-regulate to maintain the desired humidity level. The unit will automatically defrost as needed. In warmer climates defrost is not required, allowing the dehumidifier to continually dry.

If, after carrying out the above procedures, the appliance does not appear to function properly, refer to the *Trouble Shooting* section, which follows, or contact EIPL.



ROUTINE SERVICE

WARNING: ENSURE THAT THE POWER CORD TO THE MACHINE HAS BEEN DISCONNECTED BEFORE CARRYING OUT ROUTINE SERVICE. THE SERVICING AND REPAIR OF THIS UNIT SHOULD ONLY BE CARRIED OUT BY A SUITABLY QUALIFIED PERSON.

To ensure continued full efficiency of the dehumidifier, maintenance procedures should be performed as follows:

 Clean the surface of the evaporator and condenser coils by blowing the dirt out from behind the fins with compressed air. Hold the nozzle of the air hose away from the coil (approx 6") to avoid damaging the fins. Alternatively, vacuum clean the coils.

WARNING: DO NOT STEAM CLEAN REFRIGERATION COILS.

- 2. Check that the fan is firmly secured to the motor shaft and that the fan rotates freely. The fan motor is sealed for life and therefore does not need oiling.
- 3. To check the refrigerant charge, run the unit for 15 minutes and briefly remove the cover. The evaporator coil should be evenly frost coated across its surface. At temperatures above 70°F, the coil may be covered with droplets of water rather than frost. Partial frosting accompanied by frosting of the thin capillary tubes, indicates loss of refrigerant gas or low charge.
- 4. Check all wiring connections.

IF ANY OF THE PRECEDING PROBLEMS OCCUR, CONTACT THE EBAC SERVICE CENTER PRIOR TO CONTINUED OPERATION OF THE UNIT TO PREVENT PERMANENT DAMAGE.



REPAIRS

- 1. Should an electrical component fail, consult the Factory Service Center to obtain the proper replacement part.
- 2. If refrigerant gas is lost from the machine, it will be necessary to use a refrigeration technician to correct the fault. Contact the Factory Service Center prior to initiating this action.

Any competent refrigeration technician will be able to service the equipment. The following procedure must be used:

- a. The source of the leak must be determined and corrected.
- b. The machine should be thoroughly evacuated before recharging.
- c. The unit must be recharged with refrigerant measured accurately by weight.
- d. For evacuation and recharging of the machine, use the crimped and brazed charging stub attached to the side of the refrigerant compressor.
 - The charging stub should be crimped and rebrazed after servicing. **NEVER** allow permanent service valves to be fitted to any part of the circuit. Service valves may leak causing further loss of refrigerant gas.
- 3. The refrigerant compressor fitted to the dehumidifier is a durable unit that should give many years of service. Compressor failure can result from the machine losing its refrigerant gas. The compressor can be replaced by a competent refrigeration technician.

Failure of the compressor can be confirmed by the following procedure:

- a. Establish that power is present at the compressor terminals using a voltmeter.
- b. With the power disconnected, check the continuity of the internal winding by using meter across the compressor terminals. An open circuit indicates that the compressor should be replaced.
- c. Check that the compressor is not grounded by establishing that a circuit does not exist between the compressor terminals and the shell of the compressor.



TROUBLESHOOTING

<u> </u>	CAUSE	REMEDY
Unit inoperative	1. no power to unit	Check the power from the power supply panel
Little or no airflow	 Loose fan on shaft Fan motor burnt out Dirty refrigeration coils Loose electrical wiring 	 Tighten fan Replace the fan motor See Routine Maintenance Section Check the wiring diagram to find fault and repair
Little or no water extraction	 Insufficient air flow Compressor fault Loss of refrigerant gas 	 Check all of the above Contact the Factory Service Center Contact the Factory Service Center
Unit vibrates excessively	Loose compressor mounts Damaged fan	 Tighten the nuts on the compressor mounts Replace fan
Water flooding inside the machine	Drain pipe blocked/frozen Drain pipe too high	 Clear the obstruction Ensure that no section of the drain hose is above the level of the water outlet

Ebac Industrial Products, Inc. 700 Thimble Shoals Blvd, Suite 109 Newport News, VA. 23606-2575 Tel: (757) 873 6800 Fax: (757) 873 3632

Website www.ebacusa.com



SPARE PARTS LIST

Description Part Number Product Part Number 10150GY-US Controls Display PCB 1619536 Humidity Sensor PCB 1619526 PCB Timer 1619531 PCB connecting cable (700mm) 2013748 Evaporator Coil 2015024 Condenser Coil 2015025 Filter 2015028 Keypad Label 2015031
Controls Display PCB 1619536 Humidity Sensor PCB 1619526 PCB Timer 1619531 PCB connecting cable (700mm) 2013748 Evaporator Coil 2015024 Condenser Coil 2015025 Filter 2015028
Humidity Sensor PCB 1619526 PCB Timer 1619531 PCB connecting cable (700mm) 2013748 Evaporator Coil 2015024 Condenser Coil 2015025 Filter 2015028
PCB Timer 1619531 PCB connecting cable (700mm) 2013748 Evaporator Coil 2015024 Condenser Coil 2015025 Filter 2015028
PCB connecting cable (700mm) 2013748 Evaporator Coil 2015024 Condenser Coil 2015025 Filter 2015028
Evaporator Coil 2015024 Condenser Coil 2015025 Filter 2015028
Condenser Coil 2015025 Filter 2015028
Filter 2015028
Keypad Label 2015031
Coil Bracket Blanking Foam 2018724
Sponge Seal 16mm x 22mm 3015106
Capillary Tube 3014249
10mm ID insul tube 3014301
Reversing Valve 3020834
Filter Dryer 3020957
Pressure Stat 3021154
Solenoid Coil 3030454
Mains Cable 3031202
Terminal Block 3031403
25mm Open Grommet 3032111
M16 Cable Gland 3032511
M16 Gland Nut 3032512
Coil Sensor 3035142
Humidity Sensor Housing 3035164
6 Pin Socket 3037865
6 Pin Plug 3037866
Fan Wheel 3040247
Fan Inlet Ring 3040248
Jubilee Clip 3086101
PCB Mounting Pin 3101413
Contactor 3930736
Isolator 3932332
Light Pipe Lens 3931732
Compressor Capacitor 3933511
Mains Plug 3934516
PCB Connecting Cable (300mm) 3934519
PCB – Plug Cable 3935428
Condensate Drain Tube 3944115
Compressor 3944948
Fan Motor 3947037



WARNINGS

This appliance can be used by children from 8 years and above and persons with reduced physical, sensory or mental capabilities or lack of experience and knowledge if they have been given supervision or instruction concerning use of the application in a safe way and understand the hazards involved.

Children shall not play with the appliance.

Cleaning and user maintenance shall not be made by children without supervision.

If the SUPPLY CORD is damaged, it must be replaced by the manufacturer, its service agent or similarly qualified person in order to avoid hazard.

This product contains fluorinated greenhouse gases covered by the Kyoto Protocol. The refrigeration system is hermetically sealed.

The Global Warming Potential (GWP) of refrigerants used in products manufactured by Ebac Industrial Products Ltd is as follows

R410a – 2088

For type and weight of refrigerant contained in this unit, please refer to the product data label

Due to the high pressures within the refrigeration circuit, under no circumstances must direct heat be applied to the evaporator coil in an attempt to remove the build-up of ice.

No attempt should be made to cut open any part of the refrigeration circuit due to high pressures and gas involved.

If the unit is switched off at the mains power supply for any reason, the unit must be allowed to stand at rest for at least three minutes before restarting.





Drawing No. :- TPC607 Issue :- 1

Date :- 05/06/24

UK Head Office

Ebac Industrial Products Ltd St Helens Trading Estate Bishop Auckland County Durham DL14 9AD

Tel: +44 (0) 1388 664400 Fax: +44 (0) 1388 662590

> www.eipl.co.uk sales@eipl.co.uk

American Sales Office

Ebac Industrial Products Inc 700 Thimble Shoals Blvd. Suite 109, Newport News Virginia, 23606-2575 USA

Tel: +01 757 873 6800 Fax: +01 757 873 3632

www.ebacusa.com sales@ebacusa.com